

CERTIFICATE

PRESENTED TO

JANKI DEVI MEMORIAL COLLEGE

Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, Rajinder Nagar, New Delhi, Delhi 110060

Has been assessed by EHS Alliance Services for the comprehensive study of Energy Audit on institutional working framework to fulfill the requirement of

ENERGY AUDIT

ACADEMIC YEAR 2022-23

The energy-saving initiatives carried out by the institution have been verified in the report submitted and were found to be satisfactory.

The efforts taken by management and faculty towards all types of energy used in the institution and sustainability are highly appreciated and noteworthy.



31.05.2023 DATE OF AUDIT



JANKI DEVI MEMORIAL COLLEGE

ENERGY AUDIT REPORT

2022-2023

PREPARED BY
EHS ALLIANCE SERVICES





SHZ SHZ SHZ O

ΑU	JDIT CERTIFICATE	2
AC	CKNOWLEDGEMENT	3
DI	SCLAIMER	4
ΑE	BBREVIATION	5
IN	TRODUCTION OF COLLEGE	6
ΑU	JDIT PARTICIPANTS	11
EX	ECUTIVE SUMMARY	12
EN	IERGY AUDIT ANALYSIS	12
1.	ENERGY CONSUMPTION	12
2.	DIESEL CONSUMPTION	14
3.	ANALYSIS OF DG SETS	15
4.	AC SYSTEMS	17
5.	CEILING FANS ANALYSIS	19
6.	ANALYSIS OF LIGHTING SYSTEM	22
	6.1. BRIEF DESCRIPTION	22
	6.2. INVENTORY OF LIGHTING	22
	6.3. LUX MEASUREMENT	25
7.	OTHER POWER CONSUMPTION	27
	7.1 INVENTORY OF IT INFRASTRUCTURE	27
	7.2 PUMP DETAILS	27
	7.3 EXHAUST FAN DETAILS	28





CERTIFICATE



CERTIFICATE

PRESENTED TO

JANKI DEVI MEMORIAL COLLEGE

Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, Rajinder Nagar, New Delhi, Delhi 110060

Has been assessed by EHS Alliance Services for the comprehensive study of Energy Audit on institutional working framework to fulfill the requirement of

ENERGY AUDIT

ACADEMIC YEAR 2022-23

The energy-saving initiatives carried out by the institution have been verified in the report submitted and were found to be satisfactory.

The efforts taken by management and faculty towards all types of energy used in the institution and sustainability are highly appreciated and noteworthy.



31.05.2023 DATE OF AUDIT

EHS ALLIANCE SERVICES, PLOT A-72, SURYA VIHAR, GURUGRAM, 122001 WWW.EHSALL.IN | BUSINESS@EHSALL.IN | EHSALLIANCE@GMAIL.COM





ACKNOWLEDGEMENT

EHS Alliance Services would like to thank the management of Janki Devi Memorial College, University of Delhi for assigning this important work of Energy Audit. We appreciate the co-operation to the teams for completion of assessment.

We would like to specially thank *Professor Swati Pal - Principal, Janki Devi Memorial College* for giving us an opportunity to evaluate the environmental performance of the campus.

We would also like to thank **Dr Deepak Rawat** - Audit Coordinator, Janki Devi Memorial College, for his continuous support and guidance, without which the completion of the project would not have been possible. We are also thankful to other staff members who were actively involved while collecting the data and conducting field measurements.

We are also thankful to

Ms Vandana Madan	Convener, AVANI- The Environment Club, JDMC
Dr Sana Rehman	Department of Environmental Studies, JDMC
Mr Ravinder Meena	Member, AVANI- The Environment Club, JDMC
Dr Kaushal Kishore	Administrative Officer, JDMC
Mr Surendra Kumar	Administrative Officer, JDMC
Mr Avinash	Assistant - Admin, JDMC
Mr Vijay Pratap	Junior Assistant - Admin, JDMC





DISCLAIMER

EHS Alliance Services Energy Audit Team has prepared this Energy Audit Report for Janki Devi Memorial College, University of Delhi based on input data submitted by the representatives of college complemented with the best judgment capacity of the expert team.

While all reasonable care has been taken in its preparation, details contained in this report have been compiled in good faith based on information gathered.

It is further informed that the conclusions are arrived following best estimates and no representation, warranty or undertaking, express or implied is made and no responsibility is accepted by Audit Team in this report or for any direct or consequential loss arising from any use of the information, statements or forecasts in the report.

If you wish to distribute copies of this report external to your organization, then all pages must be included.

EHS Alliance, its staff and agents shall keep confidential all information relating to your organization and shall not disclose any such information to any third party, except that in the public domain or required by law or relevant accreditation bodies. EHS Alliance staff, agents and accreditation bodies have signed individual confidentiality undertakings and will only receive confidential information on a 'need to know' basis.

Vijay Singh

Lead Auditor EMS & Energy

Bern

Dr. Uday Pratap Co-Auditor EMS & Energy





ABBREVIATION

A Amps

AC Air Conditioner

AC Alternating Current

AMET Academy of Maritime Education and Training

CFL Compact fluorescent lamp

CIP Comprehensive Inspection Programme

DC Direct Current

HSD High Speed Diesel

Hz Hertz

kg Kilogram

kVA kilo-volt-ampere

kW kilo Watts

kWh kilowatt hour

kWp Kilowatt peak

LED Light Emitting Diode

LPG Liquefied Petroleum Gas

MMS Module mounting structure

MPPT Maximum Power Point Tracker

NAAC The National Assessment and Accreditation Council

SEC Specific Energy Consumption

SPV Solar Photovoltaic

STC Standard Test Condition

TV Television

V Volts

W Watts

W/m2 watt per square metre





OVERVIEW OF THE COLLEGE

Janki Devi Memorial College, a premier women's college of University of Delhi was founded in 1959 by the famous Gandhian Shri Brij Krishan Chandiwala in memory of his mother Smt. Janki Devi. JDMC aims to provide quality education to young women and empower them to become economically self-reliant, have the confidence to face the vicissitudes of a challenging society, contribute meaningfully to the society at large and acquire the capability to think, lead and change the world.




Situated in New Delhi Ridge in idyllic surroundings with its lush green lawns and imposing building, the college offers twelve under-graduate courses in Liberal Arts, Social Sciences, Mathematics and Commerce and eight post graduate courses. JDMC is the Centre for Non-Collegiate Women's Education Board (NCWEB) as well as School of Open Learning (SOL), University of Delhi. The college runs several Add-on courses/Certificate courses for students to enhance their skills. JDMC has MOUs with national and international agencies to provide the much-needed real world exposure to its students. It has more than thirty Societies/Clubs/Cells to give its students sufficient platforms to excel in various domains. The college has an extremely dedicated, committed and motivated faculty and staff.





The college offers facilities and infrastructure to create a holistic atmosphere for the pursuit of academic and extracurricular activities. JDMC has recently completed its 60-year journey in pursuit of excellence. The college has provided a nurturing environment to students from all parts of India. It has the distinction of having a disabled-friendly infrastructure along with a strong assistance system in place for the students and faculty with visual disability.

The JDMC-IQAC works in its mandated direction of internalizing and institutionalizing the quality enhancement initiatives. These initiatives encompass various stakeholders, namely students (with the aim of their integrated development), teaching staff and non-teaching staff (enhancing their capabilities and empowering them) and students' parents and Alumnae (strengthening mutually beneficial relationships).



CAMPUS

The college has an impressive building with lush green lawns, an eco-friendly campus with solar lighting and a rain-water harvesting system. The classrooms are clean, comfortable and well ventilated; the premises contain a common room and a medical





room with a sanitary napkin vending machine, an open air auditorium; a bank, a multicuisine and attractive cafeteria, computer laboratories; an audio-visual room; a photocopying centre as well as a Mother Dairy booth.



Library: JDMC library is a repository of over 1 lakh books and over 100 journals, both academic and general. It is among the first fully automated libraries in Delhi University and provides photocopying and free internet access facilities.



Labs: JDMC has 4 computer labs, 2 Research Rooms, and an A/V room. With 200+ systems and ICT facilities, these rooms provide a state-of-theart teaching/learning environment to the students and faculty.



Canteen: The college has a spacious cafeteria that offers a wide variety of snacks to students and staff at reasonable rates.



Garden: The college Gardens are a source of pride for JDMC. The gardens have won many awards in different categories in the university flower show.

Smart Classroom: The college has 3-5 smart Classrooms which are ICT enabled with interactive smart boards to facilitate the teaching-learning process.

Seminar room: The Seminar Room has a seating capacity of more than 200 with a state-of-the-art audio-visual system which is updated on a regular basis. The Seminar Room functions as a multi-purpose space used to hold conferences, seminars, workshops, meetings etc.





/ISION | MISSION | CORE VALUES

JDMC, a premier women's college of University of Delhi, endeavours to promote enduring knowledge which is global in its perspective and yet local in its relevance. Students are challenged & inspired to pursue excellence in liberal and performing arts, humanities, commerce and sports, in an environment which is vibrant & constantly evolving. Founded with a vision to empower women, JDMC continues to strive to help its students to develop a capacity to think, lead and change the world.

MISSION STATEMENT AND CORE VALUES

The egalitarian approach of the institution promotes the inclusion of all sections of the society. The institution is equally inclusive of all its constituencies, with their respective duties, responsibilities and achievements. The students and staff, belonging to diverse classes, castes, ethnic and religious groups cooperate in a democratic environment to take the college to newer heights of excellence. The institution besides providing education, also serves as a platform for cultural expression and excellence, constantly reminding students of the primary importance of cultural diversity, national integration and tolerance, along with the need to be in harmony with the environment

Janki Devi Memorial College is committed to the following core values:


- The foundational ideal is enshrined in the upanishadic motto of the college itself, 'Vidyahi paramam Jyoti'-Knowledge is Eternal Light
- Gandhian philosophy of responsible citizenship and empowerment of women through education
- Imparting knowledge based on traditional values, yet with modern and global significance in an evolving academic world
- Education, in combination with technological skills, empowers the students both academically and economically, and proactively contributes to their brighter future


Therefore, the college creates a motivational environment to provide holistic education and personality development of the students, resulting in a synthesis of their career growth and ethical and responsible citizenship





JDMC is providing education to undergraduates and graduates in following department.










AUDIT PARTICIPANTS

On behalf of College

Name	Designation
Professor Swati Pal	Principal, JDMC
Ms Vandana Madan	Convener, AVANI- The Environment Club, JDMC
Dr Deepak Rawat	Department of Environmental Studies, JDMC
Dr Sana Rehman	Department of Environmental Studies, JDMC
Mr Ravinder Meena	Member, AVANI- The Environment Club, JDMC
Dr Kaushal Kishore	Administrative Officer, JDMC
Mr Avinash	Assistant - Admin, JDMC
Mr Vijay Pratap	Junior Assistant - Admin, JDMC

On behalf of EHS Alliance Services

Name	Position	Qualifications			
Vijay Singh	Lead	M.Sc. M. Tech (Environment Science &			
	Auditor	Engineering), Energy Auditor, Post			
		Diploma in Industrial Safety			
		Management			
Dr. Uday Pratap	Co-	Ph.D., Lead Auditor ISO 14001:2015,			
	Auditor	PDIS, QCI – WASH			







EXECUTIVE SUMMARY

The purpose of this Energy Audit was to seek opportunities to improve the energy efficiency of the Janki Devi Memorial College. Reducing the energy consumption despite improving the human comfort, health and safety were of primary concern.

Beyond just identifying the energy consumption pattern, this audit sought to detect and categorize the most energy efficient appliances. Additionally, some daily practices relating common appliances have been shared which may help reducing the energy consumption. Data collection for energy audit of the campus was carried out by the EHS Alliance Team. The Energy Audit Report accounts for the energy consumption patterns of the institution on actual survey and detailed analysis during the audit.

The work comprehends the area wise consumption traced using suitable equipment. The analysis was carried out by our team with the support of the staff members from Janki Devi Memorial College. The report provides a list of possible actions to preserve and efficiently access the available source, resources and their saving potential was also identified. We look forward towards optimization that the authorities, students and staff members would follow the recommendations in the best possible way. The report is based on certain generalizations including the approximations wherever necessary. The views conveyed may not reveal the general opinion. They merely represent the opinion of the team guided by the interviews of clients. We are happy to submit this Energy audit report to the Janki Devi Memorial College.

ENERGY AUDIT - ANALYSIS

1. ENERGY CONSUMPTION

To understand the Energy Consumption trends and for analyzing the average monthly consumption we have collected electricity energy bills from June 2022 to May 2023

The details of "Meter Connection" at "Janki Devi Memorial College" are as follows-

Name - The Principal

CA No. - 100001930






1.1 Summary of Monthly Electricity Consumption and Total Bill Amount


To understand the Energy consumption trend and for developing the baseline parameter we have collected monthly energy bill for the 12 months i.e. from June 2022 to May 2023

			Solar	Net Metering	
Month	Grid Units	Amount	Units	Units	Amount
Jul-22	49703	8.50	3,783	45920	390323
Aug-22	51914	8.50	2,898	49016	416634
Sep-22	51651	8.50	3,010	48641	413449
Oct-22	42347	8.50	2,977	39370	334647
Nov-22	28320	8.50	1,879	26441	224745
Dec-22	27104	8.50	2,126	24978	212315
Jan-23	35200	8.50	2,223	32977	280308
Feb-23	30720	8.50	2,477	28243	240067
Mar-23	33504	8.50	3,520	29984	254861
Apr-23	28848	8.50	6,326	22522	191435
May-23	38865	8.50	3,904	34961	297170
Jun-23	50000	8.50	4,000	46000	391000
SUM	468176		39123	429053	3646954










2. DIESEL CONSUMPTION

Below is the diesel consumption details in litres from from June 2022 to May 2023.

Period	Diesel consumption (in litres)
Jun-22	35
Jul-22	40
Aug-22	25
Sep-22	65
Oct-22	44
Nov-22	27
Dec-22	25
Jan-23	25
Feb-23	10
Mar-23	100
Apr-23	25
May-23	25
Total	446







3. ANALYSIS OF DG SETS

In the campus, there are 3 Diesel Generator (DG) set for its electrical power needs in case of Grid power failure. DG sets capacity is 347.5 kVA.

DG Set Design Details

Description	Unit	DG Station -1	DG Station -2	DG Station -3
Design details:				
Rated capacity	kVA	125 kva	160	62.5 kva
Hz		50	50	50
Sl No.		6H.3516/0801590	1308061708370	1308031807948
Make		kirloskar	Greaves	Greaves
Volts	Volts	415	415	415
PF		0.8	0.8	0.8
Phase		3	3	3
RPM		1500	1500	1500
Amps	Amps	173.9	223	87
Mfg.		Aug 2008	Aug 2017	July 2018





DG Set Operation details								
Operating hours during testing	Hours	0.5						
% Loading	%	62.47						
Energy Generation	kWh	34.84						
Load	kVA	70.41						
Fuel consumption during testing	Litre	8						
Specific energy generation	kWh/litre	3.27						

Observation and Suggestions:-

Soundproof silent generators are an efficient tool to keep both noise and vibration at low levels. For the power backup of the institution, the soundproof model is installed in the institution.

As per the trial taken during the energy audit the percentage loading of DG set is 70.41% which is ok and specific energy consumption of DG Sets 3.27 kWh/Litre which is satisfactory because as per manufacturer recommendation, best practices for SEC in DG sets range from 3.0 to 3.5 kWh/Litre and above.

We recommend college to initiate stack monitoring of DG set through authorized lab.







4. AC SYSTEM

Energy Efficiency Ratio (EER): Performance of smaller chillers and rooftop units is frequently measured in EER rather than kW/ton. EER is calculated by dividing a chiller's cooling

Capacity (in Btu/h) by its power input (in watts) at full-load conditions. The higher the EER, the More efficient the unit. The cooling effect produced is quantified as tons of refrigeration (TR). The above TR is also called as air-conditioning tonnage.

There are Split ACs installed in Janki Devi Memorial College, University of Delhi in various areas of various capacity which detail is given below:-

Split AC – 35 Windows AC – 44 Total installed AC – 79

SI No.	Location/Identification	AC Type	Count	TR in Tons	Room Temp. (°C)	AC-Tout (°C)	AC-Tin (°C)	Room-RH (%)	Area (m2)	Air velocity (m/s)	Enthalpy Hout	Enthalpy Hin	Heat Load in TR	KW supplied	(Eff.) Power per Ton (KW /TON)	EER
1	Library	S	4	1.5	24	12	20	52	0.03	2.2	25	38	0.32	0.55	1.72	2.04
2	Library	W	7	1.5	24	11	19	52	0.03	2.6	24	37	0.38	0.57	1.52	2.31
3	GCR	W	1	1.5	24	10	18	52	0.03	2.4	24	37	0.35	0.53	1.53	2.3
4	Seminar	S	1	1.5	23	12	20	52	0.03	2.3	25	38	0.33	0.55	1.67	2.11
5	Seminar	W	4	1.5	23	11	19	52	0.03	2	22	37	0.33	0.58	1.74	2.02
6	Committee	S	1	1.5	23	13	20	52	0.03	2.3	26	38	0.31	0.53	1.74	2.02
7	Committee	W	2	1.5	23	12	20	52	0.03	2.2	25	38	0.32	0.55	1.74	2.03
8	Medical	S	1	1.5	23	12	19	52	0.03	2.3	24	37	0.33	0.58	1.74	2.02
9	Audi Control room	W	1	1.5	24	12	20	52	0.03	2.2	25	38	0.32	0.55	1.72	2.04
10	Bank	S	2	1.5	24	11	19	52	0.03	2.6	24	37	0.38	0.57	1.52	2.31
11	Union Room	W	1	1.5	24	10	18	52	0.03	2.4	24	37	0.35	0.53	1.53	2.3
12	Principal Anty Room	S	1	1.5	23	12	20	52	0.03	2.3	25	38	0.33	0.55	1.67	2.11
13	Lab II,III	S	3	1.5	23	11	19	52	0.03	2	22	37	0.33	0.58	1.74	2.02





14	Lab II,III	W	2	1.5	23	13	20	52	0.03	2.3	26	38	0.31	0.53	1.74	2.02
15	Server room	S	2	2	23	12	20	52	0.03	2.2	25	38	0.32	0.55	1.74	2.03
16	Admin	S	2	1.5	23	12	19	52	0.03	2.3	24	37	0.33	0.58	1.74	2.02
17	A0	S	1	1.5	24	12	20	52	0.03	2.2	25	38	0.32	0.55	1.72	2.04
18	SO SO	S	1	1.5	24	11	19	52	0.03	2.6	24	37	0.38	0.57	1.52	2.31
19	AUDIO VIDEO ROOM	S	2	2	24	10	18	52	0.03	2.4	24	37	0.35	0.53	1.53	2.3
20	Music	S	1	1.5	23	12	20	52	0.03	2.3	25	38	0.33	0.55	1.67	2.11
21	Music	W	1	1.5	23	11	19	52	0.03	2	22	37	0.33	0.58	1.74	2.02
22	Staff Room	S	2	1.5	23	13	20	52	0.03	2.3	26	38	0.31	0.53	1.74	2.02
23	Staff Room	W	2	1.5	24	12	20	52	0.03	2.2	25	38	0.32	0.55	1.72	2.04
24	STA Room	S	1	1.5	24	11	19	52	0.03	2.6	24	37	0.38	0.57	1.52	2.31
25	PA	S	1	1.5	24	10	18	52	0.03	2.4	24	37	0.35	0.53	1.53	2.3
26	Principal OffIce	S	2	1.5	23	12	20	52	0.03	2.3	25	38	0.33	0.55	1.67	2.11
27	Account	S	1	1.5	23	11	19	52	0.03	2	22	37	0.33	0.58	1.74	2.02
28	Account	W	2	1.5	23	13	20	52	0.03	2.3	26	38	0.31	0.53	1.74	2.02
29	Sports	S	1	1.5	23	12	20	52	0.03	2.2	25	38	0.32	0.55	1.74	2.03
30	Sports	W	1	1.5	23	12	19	52	0.03	2.3	24	37	0.33	0.58	1.74	2.02
31	PIO	W	1	1.5	24	12	20	52	0.03	2.2	25	38	0.32	0.55	1.72	2.04
32	Department	W	1	1.5	24	11	19	52	0.03	2.6	24	37	0.38	0.57	1.52	2.31
33	Research Room Lab2	S	3	2	24	10	18	52	0.03	2.4	24	37	0.35	0.53	1.53	2.3
34	Research Room staff room	S	1	1.5	23	12	20	52	0.03	2.3	25	38	0.33	0.55	1.67	2.11
35	Hostel	S	5	1.5	23	11	19	52	0.03	2	22	37	0.33	0.58	1.74	2.02
36	Hostel	W	18	1.5	23	13	20	52	0.03	2.3	26	38	0.31	0.53	1.74	2.02

Remarks: - We have checked Energy Efficiency Ratio of AC's and EER of AC's is fairly OK. But in future you should purchase 5-Star rated invertor based split AC's because power consumption of Inverter based BEE 5-Star rated AC's is less than non-star rated AC's.

Also, we recommend Janki Devi Memorial College, University of Delhi to organize periodic maintenance schedule and take corrective actions for insulating of AC's refrigerant lines in order to protect energy losses.









5. FANS ANALYSIS

In the Janki Devi Memorial College, there are 344 fans installed.

Ceiling Fan (70 W) - 65

Ceiling Fan (240 W) - 279

The observation and suggestion are given below.

Sl No.	Location/Identification	Ceiling Fan 240W	Ceiling Fan-70W
1	Seminar	8	
2	Staff Room	6	
3	Research Room	2	
4	Canteen	24	
5	Control Room (Audi)	0	
6	Auditorium	24	
7	1	5	
8	2	5	
9	3	3	
10	4	3	
11	5	3	
12	6	2	
13	7 AV	5	
14	8	5	
15	11(ncweb)	7	





16	12	7	
17	13	7	
18	13A	2	
19	14	7	
20	15 A/V	7	
21	16 A/V	7	
22	17	5	
23	17A	5	
24	18Tut	2	
25	19Tut	2	
26	20Tut	2	
27	21Tut	1	
28	22Tut	1	
29	23Tut	1	
30	24Tut	1	
31	25Tut	1	
32	26Tut	1	
33	27Tut	1	
34	28Tut	1	
35	29Tut	1	
36	30Tut	2	
37	31Tut	1	
38	32Tut	1	
39	33Tut	2	
40	34Tut	1	
41	35Tut	1	
42	36Tut	3	
43	60Tut	2	
44	38	2	
45	39A	3	
46	39	3	
47	40 A/V	7	
48	41A	3	
49	41	3	
50	42 A/V	5	
51	43	2	2
52	43A	4	1
53	56	2	
54	52		2
55	53	2	2





56	54		2
57	55	4	4
58	NCC	2	
59	57	2	
60	58	2	
61	44	5	
62	45	5	
63	46	5	
64	47	5	
65	48	5	
66	49	3	
67	L1-20	3	
68	L2-20	3	
69	1	4	
70	2	2	
71	3	2	
72	II -	4	
73	III	10	
74	61		2
75	62		2
76	63		4
77	64		4
78	65		8
79	66 A/V		8
80	67		8
81	68 A		8
82	69		8
	TOTAL	279	65

Observation and Suggestions:-

In the college, old ceiling majority of fans are of 250 W but BEE 5 Star Rated of 30W Ceiling Fans are present in the market. Therefore we suggest to replace BEE 5 Star rated fans of 30W.

Note:- Energy saving will increase or decrease if operating hours of machine /equipment will be increased or decreased and payback period will also increase or decrease if cost of investment (Cost of machine/equipment/accessories of machine) will increase or decrease because cost of investment is taken on tentative basis.





ECRM-1-Energy saving by replacing 70/250 W fans with energy efficient 30W ceiling fans

Total no of Ceiling Fans (70W)		65	Nos.
Total no of Ceiling Fans (250W)		279	Nos.
Total wattage of 70W Ceiling Fans	=	4550	Watt
Total wattage of 250W Ceiling Fans	=	69750	Watt
Total wattage of BEE 5 Star rated Fans (30W)	=	10320	Watt
Total saving in Wattage after replacement	=	63980	Watt
Operating hours per day	=	8	Hours
Operating days per annum	=	180	Days
Energy charges per unit in Rs.	=	8.5	INR
Saving in Rs./annum	=	783115.20	INR
Investment INR	=	1032000	INR
Payback period:- Months	=	0.75	YEARS

6. ANALYSIS OF LIGHTING SYSTEM

6.1 Brief description of existing system

For assessing energy efficiency of lighting system, Inventory of the Lighting System has been noted / collected, with the aid of a lux meter, measurement and documentation of the lux levels at various locations at working level has been done.

6.2 Inventory of Lighting

SI. No.	Location/ Identification	200W- LED High Mast	solar light LED	24W LED Light	12 W LED Round	50W LED	40W Tube light	18W LED Flood	20W LED
1	1								4
2	2								4
3	3								5
4	4								5
5	5								5
6	6								3
7	7 AV								7
8	8								7
9	12								11





10	12	11
-	13	11
11	13A	3
12	14	11
13	15 A/V	11
14	16 A/V	11
15	17	4
16	17A	4
17	18Tut	2
18	19Tut	2
19	20Tut	2
20	21Tut	2
21	22Tut	2
22	23Tut	2
23	24Tut	2
24	25Tut	2
25	26Tut	2
26	27Tut	2
27	28Tut	2
28	29Tut	2
29	30Tut	2
30	31Tut	2
31	32Tut	2
32	33Tut	2
33	34Tut	2
34	35Tut	2
35	36Tut	3
36	38	2
37	39A	6
38	39	5
39	40 A/V	11
40	41A	6
41	41	6
42	42 A/V	8
43	43	4
44	43A	8
45	Admin	45
46		8
70	Account	Ö





47	52	2
48	53	2
49	54	2
50	55	6
51	NCC Room	2
52	57	2
53	58	3
54	59	4
55	44	8
56	45	8
57	46	8
58	47	8
59	48	8
60	49	8
61	L1-20	3
62	L2-20	3
63	L3-20	4
64	L4-20	2
65	Corridor lib	5
66	Computer Lab I	18
67	Computer Lab II	9
68	Computer Lab III - AV	16
69	Sports Room	16
70	Sports Changing	5
71	61	4
72	62	4
73	63	6
74	64	6
75	65	12
76	66 A/V	12
77	67	12
78	68 A	12
79	69 A/V	12
80	Library	209
81	Principal	4
82	Committee	10
83	Staff Room	53





84	Research room								14
85	Prta cabin								10
86	Corridors								49
87	Taress	13							
88	Toilet Admin		3						
89	Audi					12	12		
90	building back side								
91	Entrance Main Road		7						
	Total	13	10	0	0	12	12	0	835

6.3 Lux Measurement

Description	Lux	Remark
Class Rooms	120 to 235	Acceptable
Offices	130 to 240	Acceptable
Corridors	35 to 90	Acceptable
Washrooms	45 to 76	Acceptable
Outdoor	36 to 95	Acceptable
Computer Lab	150 to 289	Acceptable
Parking area	45 to 94	Acceptable
Canteen	69 to 185	Acceptable

Observation

College has implemented LED based lighting solution in the campus. LEDs save energy, the life span is much greater and emit virtually no heat. College has installed solar lights for street lights in the campus. JDMC is doing their bit for the energy conservation. We recommend to install motion sensor-based lights in common areas such as library, washrooms, corridors, etc.

We also recommend to use solar lights for open areas like parking, ground, street lights, etc. Table below shows the performance characteristics comparison of all luminaries.





Table - Luminous Performance Characteristics of Commonly Used Luminaries							
Type of Lamp	f Lamp Lumens/Watt		Colour	Typical Application	Typical Life		
	Range	Avg.	Rendering Index				
Incandescent	8-18	14	Excellent (100)	Homes, restaurants, general lighting emergency lighting	1000		
Fluorescent lamps	46-60	50	Good w.r.t coating (67- 77)	Offices, shops, hospitals, homes	5000		
Compact fluorescent Lamps (CFL)	40-70	60	Very Good (85)	Hotels, shops, homes, offices	8000-10000		
High pressure mercury (HPMV)	44-57	50	Fair (45)	General lighting in factories, garages, car parking. flood lighting	5000		
Halogen lamps	18-24	22	Excellent (100)	Display, flood lightening, stadium exhibition grounds, construction areas	2000 - 4000		
High pressure sodium (HPSV) SON	67-121	90	Fair (22)	General lighting in ware houses, factories, street lighting	6000 - 12000		
Low pressure sodium (LPSV) SOX	101-175	150	Poor (10)	Roadways, tunnels, canals, street lighting	6000 - 12000		
Metal halide lamps	75-125	100	Good (70)	Industrial bays, spot lighting, flood lighting, retail stores	8000		
LED Lamps	30-50	40	Good (70)	Reading lights, desk lamps, night lights, spotlights, security lights, signage lights, etc.	40000 - 100000		





7. OTHER POWER CONSUMPTION

7.1 Inventory of IT Infrastructure

Sl No.	Location/Identification	Desktop	Laptop	Printers	Scanners	Servers	Other
1	Computer Lab I		32	1			
2	Computer Lab II	49	14	2			
3	Computer Lab III	50		2	1		
4	Research Room	8		1			
5	Library	9-DU HP (5- comp.3- HP=8)	24	3+1+1 id		1	
6	Admin	6		6			
7	SO SO	1					
8	Account	8		5		1	
9	Principle Off	1	2	1			
10	Committee	1					
11	PA	1		1			
12	AO office	1		1			
13	Sports	1		1			
14	Server Room	1		1			3
15	E Resource Centre		43				
	Total	128	115	22	1	2	3

7.2 Water pump details

Sr. No	Description	Unit	Pump No1	Pump No2
1	Rated Power of Motor	KW 1 35/50		0.75/1.0
2	Motor Eff.	%	6%	6%
3	Discharge Head	m	6.1/0.6 LPH	2800-880 LPH
4	Suction Head	m	36/52	18-45
5	Pump Type	Submersible/ Monoblok/Centrifug al Etc.	submersible pump	Submersible Monoblock





7.3 Other Loads

SI No.	Location/Ident ification	60W Exhaust Fan	160W Exhaust Fan	Other 3phase	Single phase 230 W	180W- Circulating Fan	Solar panel 50.22 kilowatt capacity	Solar water heater
1	Composting Machine			415- 440 Volts / 50 Hz				
2	Canteen		3					
3	Toilet/Library	15						
4	Drinking water cooler 8				8			
5	Fridge				8			
6	Water dispenser				4			
7	Auditorium					2		
8	Building Roof Area & Library Roof Area						162 Module/panel	
9	hostel room area							tank 1000 ltr single phase 230w

ANALYSIS: There should be regular maintenance schedule of equipment like pumps, exhaust fans, water coolers and IT equipment. Electronics such as computers, printers, scanners, etc. more than 3 year or 5 years (as per their life) should be replaced with new computers/laptops. Ideal Temperature should be maintained for all electronic appliances.

8. CAPACITOR BANK

Sl. No.	Identification	Capacity in KVAR
1	Substation I	25 KVAR

**** **END OF THE REPORT** *****