



Basic Details

Organisation Chain	University Grants Commission University of Delhi Janki Devi Memorial College		
Tender Reference Number	JDMC/EW/2026-27/1007		
Tender ID	2026_UGC_851585_1		
Tender Type	Open Tender	Form of contract	Works
Tender Category	Works	No. of Covers	2
Payment Mode	Not Applicable	Is Multi Currency Allowed For BOQ	No
Is Multi Currency Allowed For Fee	No		

Cover Details, No. Of Covers - 2

Cover No	Cover	Document Type	Description
1	Fee/PreQual/Technical	.pdf	Tender Documents
2	Finance	.xls	BOQ

Tender Fee Details, [Total Fee in ₹ * - 0.00]

Tender Fee in ₹	0.00		
Fee Payable To	NA	Fee Payable At	NA
Tender Fee Exemption Allowed	NA		

EMD Fee Details

EMD Amount in ₹	0.00	EMD Exemption Allowed	NA
EMD Fee Type	NA	EMD Percentage	NA
EMD Payable To	NA	EMD Payable At	NA

Work / Item(s)

Title	Electrical safety and repair works at Janki Devi Memorial College				
Work Description	Electrical safety and repair works at Janki Devi Memorial College				
Pre Qualification Details	Please refer Tender documents.				
Tender Value in ₹	4,79,611	Product Category	Job Works	Sub category	NA
Contract Type	Tender	Bid Validity(Days)	90	Period Of Work(Days)	90
Location	Janki Devi Memorial College	Pincode	110060	Pre Bid Meeting Place	NA
Pre Bid Meeting Address	NA	Pre Bid Meeting Date	NA	Bid Opening Place	Janki Devi Memorial College

Critical Dates

Publish Date	18-Sep-2026 05:00 PM	Bid Opening Date	05-Oct-2026 03:30 PM
Document Download / Sale Start Date	18-Sep-2026 05:00 PM	Document Download / Sale End Date	05-Oct-2026 03:00 PM
Clarification Start Date	NA	Clarification End Date	NA
Bid Submission Start Date	18-Sep-2026 05:00 PM	Bid Submission End Date	05-Oct-2026 03:00 PM

Tender Documents

NIT Document	S.No	Document Name	Description	Document Size (in KB)	
	1	Tendernotice_1.pdf	NIT	297.25	
Work Item Documents	S.No	Document Type	Document Name	Description	Document Size (in KB)
	1	Tender Documents	ElectricalSafetyWorks.pdf	Tender Documents	297.25

Tender Inviting Authority

Name	Principal
Address	Janki Devi Memorial College Sir Ganga Ram Hospital Marg New Delhi 110060

Tender Creator Details

Created By	Swati Pal
------------	-----------

Designation	Principal
Created Date	18-Sep-2026 04:32 PM

JANKI DEVI MEMORIAL COLLEGE

(University of Delhi)

Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, New Delhi 110060

E-PUBLISHING TENDER TENDER DOCUMENT

Name of work	Electrical safety and repair works at Janki Devi Memorial College, New Delhi
Tender reference	JDMC/EW/2026-27/1007
Estimated cost	Rs 4,79,611, excluding goods and services tax
Completion period	90 days
Bid system	Two covers: technical and financial
Last date and time	05.10.2026 at 15:00 hours

The notice inviting tender and this document are published on the Central Public Procurement Portal and on the College website.

Bids are to be submitted in sealed hard copy at the office of the Principal. Bids are not received online.

Tender invited by the Principal, Janki Devi Memorial College

September 2026

Prepared by RSA Architects LLP, Architect Consultant

1. Tender schedule

Table 1 — Tender schedule. Every date, amount and period of this tender is fixed in this table. Where any other part of this document, or any annexure, states a date, amount or period differently, this table governs.

Item	Entry
Name of work	Electrical safety and repair works at Janki Devi Memorial College, New Delhi
Tender reference	JDMC/EW/2026-27/1007
Employer	Janki Devi Memorial College (University of Delhi), Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, New Delhi 110060
Estimated cost put to tender	Rs 4,79,611 (Rupees Four lakh seventy-nine thousand six hundred and eleven only), excluding goods and services tax. Basis: CPWD Delhi Schedule of Rates (E&M) 2025 read with Correction Slip No. 1, taken at par, and non-schedule items on rate analysis.
Cost of tender document	Nil. No cost is charged for a document downloaded by a bidder.
Earnest money	Not applicable. A bid securing declaration at Annexure D is required in its place.
Publication of the notice	18.09.2026, on the Central Public Procurement Portal and on the College website
Download of the tender document	18.09.2026 at 14:00 hours to 05.10.2026 at 15:00 hours
Last date for queries	28.09.2026 at 15:00 hours
Pre-bid conference	Not applicable
Last date and time for receipt of tenders	05.10.2026 at 15:00 hours, office of the Principal
Opening of the technical bid	05.10.2026 at 15:30 hours
Period of bid validity	90 days, counted from the day after the last date of receipt of tenders. The ninetieth day is 03.01.2027, a Sunday, so validity runs to the next working day, 04.01.2027
Financial bid format	Annexure I of this document. It is to be detached, priced, signed on every page and enclosed in Cover 2
Period of completion	90 days from the date of start
Date of start	The tenth day from the date of the letter of intent
Defect liability period	12 months from the certified date of completion (clause SC-24)
Liquidated damages	1 per cent of the contract value per week of delay, subject to a maximum of 5 per cent of the contract value
Performance guarantee	5 per cent of the tendered amount, within 7 days of the letter of intent. It may be furnished, at the contractor's option, as a demand draft in

Item	Entry
	favour of the College, a fixed deposit receipt of a scheduled bank pledged to the College, or a bank guarantee in the form at Annexure H. A fixed deposit receipt or bank guarantee shall be valid 60 days beyond completion of all obligations including the defect liability period
Security deposit	2.5 per cent of the tendered amount, recovered at 2.5 per cent of the gross amount of each running and final bill
Minimum value of a running account bill	Rs 2,00,000
Price variation	Not applicable. The contract is on a firm-price basis.
Contact for clarifications	The Principal, Janki Devi Memorial College, telephone 011-49876630, email principal@jdm.du.ac.in

2. Notice inviting tender

2.1 The Principal, Janki Devi Memorial College (University of Delhi), invites sealed item-rate tenders in two covers, technical and financial, for the electrical safety and repair works at the College, estimated cost put to tender Rs 4,79,611 (Rupees Four lakh seventy-nine thousand six hundred and eleven only) excluding goods and services tax, period of completion 90 days.

2.2 The tender document may be downloaded free of cost from the Central Public Procurement Portal, <https://eprocure.gov.in>, and from the College website, <https://jdm.du.ac.in>, from 18.09.2026 at 14:00 hours to 05.10.2026 at 15:00 hours.

2.3 Sealed tenders are to reach the office of the Principal, Janki Devi Memorial College, Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, New Delhi 110060 on or before 05.10.2026 at 15:00 hours. Technical covers will be opened the same day at 15:30 hours in the presence of the bidders' representatives who choose to attend.

2.4 Eligibility in brief: a valid electrical contractor licence issued in Delhi, goods and services tax registration, permanent account number, and one similar work of not less than Rs 2,40,000 completed in the last seven years. The full criteria are at section 4.

2.5 The College is not bound to accept the lowest or any tender. This tender is invited by the Principal, Janki Devi Memorial College.

3. Instructions to bidders

3.1 Download of the document

The complete tender document is available for download free of cost from the portal and the College website for the period in Table 1. The bidder shall download every corrigendum issued up to the last date of receipt of tenders. Every corrigendum forms part of this tender document.

3.2 Queries

Queries are to reach the College by email by the date in Table 1. Replies and any resulting amendment will be issued as a corrigendum on the portal and the College website. No pre-bid conference will be held for this work.

3.3 Inspection of site

The bidder is advised to inspect the site before tendering. Inspection may be arranged on any working day between 11:00 and 16:00 hours through the College office.

3.4 Contents of the covers

Cover 1, technical bid: the documents listed at section 5. Cover 2, financial bid: Annexure I only, priced, totalled and signed on every page. Nothing else is to be put in Cover 2. A financial figure appearing anywhere in Cover 1 will cause the tender to be rejected.

3.5 Sealing and marking

The two inner covers shall be sealed and marked “Technical Bid” and “Financial Bid”, placed in one sealed outer cover marked with the name of work, the tender reference, and the bidder's name and address.

3.6 Submission

The tender shall reach the office of the Principal by the date and time in Table 1. A tender received after that time will be returned unopened. Delay in transit is not a ground for late receipt.

3.7 Bid securing declaration

Earnest money is not taken. The bidder shall submit the bid securing declaration at Annexure D. By it the bidder accepts suspension from tendering with the College for one year if it withdraws or modifies its tender during the period of validity, or, being the successful bidder, fails to furnish the performance guarantee or to sign the agreement. Such failure may attract action under the rules in force, including debarment.

3.8 Rates and taxes

Rates shall be quoted excluding goods and services tax. Tax shall be paid extra at the rate in force. Tenders will be compared on the total quoted amount excluding goods and services tax.

3.9 Bid validity

Tenders shall remain valid up to and including 04.01.2027, being 90 days counted from the day after the last date of receipt of tenders, the ninetieth day falling on a Sunday and validity therefore running to the next working day. A tender offering a shorter validity will be rejected as non-responsive.

3.10 Opening

The technical bids will be opened at the date and time in Table 1. The financial bids of technically qualified bidders only will be opened on a date notified to them. The College will record an attendance sheet and an opening report.

3.11 Evaluation and award

Technical bids will be evaluated against section 4. Among qualified bids, the bid quoting the lowest total price excluding tax will be declared L1 and the contract awarded to it. Arithmetical errors will be corrected. Where a rate differs in figures and in words, the rate in words governs. The contract will be awarded within the original bid validity.

3.12 Single bid

Receipt of a single bid will not by itself be treated as a failure of competition.

3.13 Negotiation

Negotiation, if any, will be conducted only with the lowest evaluated responsive bidder and only in exceptional circumstances, with reasons recorded. No revised rate from any other bidder will be entertained.

3.14 Corrigendum

Any amendment will be issued as a corrigendum, published in the same manner as this notice. A minor amendment will carry an extension of the last date by not less than three days. A substantial amendment will carry an extension consistent with the original bid preparation time.

3.15 Grounds for rejection

A tender will be rejected if it is received after the deadline; is not signed by the authorised signatory; omits the bid securing declaration; omits a document listed at section 5; offers a shorter validity; is conditional; discloses a financial figure in the technical cover; quotes nil rates; or is submitted by a bidder that is debarred or has made a false declaration.

3.16 Rights of the College

The College is not bound to accept the lowest or any tender. It may increase or decrease quantities and omit items, and the contractor shall carry out the work at the quoted rates. The work will be awarded to one contractor as a single package.

4. Eligibility criteria

Table 2 — Eligibility criteria. Each criterion is to be met on the last date of receipt of tenders and proved by the document named.

#	Criterion	Requirement	Proof
1	Constitution	The bidder is a proprietorship, partnership, limited liability partnership, company, society or trust, registered as such	Self-attested copy of the registration, partnership deed or certificate of incorporation
2	Electrical contractor licence	A valid licence to execute electrical works, issued by the Licensing Board, Government of the National Capital Territory of Delhi, valid on 05.10.2026. The contractor shall deploy a certified supervisor and licensed wireman on this work	Self-attested copy of the licence and of the supervisor's certificate of competency
3	Statutory registrations	Goods and services tax registration and permanent account number; registration under the employees' provident fund and employees' state insurance schemes where applicable to the bidder	Self-attested copies
4	Similar work	One work of electrical repair, maintenance or installation in a building, including panel work, earthing or cabling, of value not less than Rs 2,40,000, completed in the last seven years ending 31.08.2026	Completion certificate from the employer or its engineer showing the name of work, the executed cost and the dates of start and completion; particulars at Annexure C

#	Criterion	Requirement	Proof
5	Bid securing declaration	Submitted in the form at Annexure D	Annexure D
6	Not debarred	The bidder is not debarred by the Department of Expenditure, by the College or by any other procuring entity, and discloses any transgression of the Code of Integrity in the last three years	Affidavit at Annexure E
7	Labour compliance	The bidder undertakes to comply with the labour laws in force and to hold every registration and licence required for this work	Undertaking at Annexure F
8	Make in India	The bidder declares whether it is a Class-I local supplier, a Class-II local supplier or a non-local supplier, and states its percentage of local content	Certificate at Annexure G

4.1 A recognised startup is relaxed from the requirement of prior experience at row 4 of Table 2. No other criterion is relaxed. The electrical contractor licence at row 2 is required of every bidder without exception.

5. Checklist of documents for the technical bid

Table 3 — Checklist. The bidder shall enclose each document in Cover 1 and tick the box. Annexure I, the priced financial bid, goes in Cover 2 and must not appear in Cover 1.

#	Document	Enclosed
1	Tender acceptance letter, Annexure A	[]
2	Bidder's details, Annexure B	[]
3	Registration, partnership deed or certificate of incorporation	[]
4	Electrical contractor licence, and supervisor's certificate of competency	[]
5	Goods and services tax registration certificate	[]
6	Permanent account number card	[]
7	Provident fund and state insurance registration, where applicable	[]
8	Completion certificate of the similar work, with particulars at Annexure C	[]
9	Bid securing declaration, Annexure D	[]
10	Affidavit that the bidder is not debarred, Annexure E	[]
11	Undertaking on compliance with the Labour Codes, Annexure F	[]
12	Make in India local-content certificate, Annexure G	[]
13	Signed copy of every page of this tender document and of every corrigendum	[]

6. Scope of work and site particulars

6.1 Site. The campus of Janki Devi Memorial College, Sir Ganga Ram Hospital Marg, Old Rajinder Nagar, New Delhi 110060. The campus is occupied and includes a girls' hostel, an administration block, the Janki Devi Vocational Centre, a library, an auditorium and a canteen, with a transformer yard and a diesel generator yard.

6.2 The work is the rectification of the electrical installation found defective in the energy audit, the electrical safety audit and the thermal imaging report of October 2024, and comprises:

- (a) checking all main panels with a thermal camera before the repair work starts and again after it is finished, with a photographic report;
- (b) servicing of fifteen panels, and replacement of burnt fuse units, circuit breakers and cable ends where found necessary;
- (c) making loose and damaged cables safe, including the transformer-yard cables, the generator-yard cables and the open wires at the hostel and vocational centre panel room;
- (d) earthing: opening up twelve buried earth pits with new chambers and tests, and up to ten new earth pits with connecting strips;
- (e) safety items at panel rooms, the generator yard and the transformer yard: danger boards, insulating mats, fire extinguishers, sand buckets, first-aid sets, exhaust fans and lighting;
- (f) load balancing of ten distribution panels and preparation of a wiring chart of the campus with three framed prints.

6.3 Limits of the work. The work is limited to the items of the schedule of quantities and to nothing else. Two boundaries apply. First, the transformer and its earthing and equipment are maintained by the distribution licensee, BSES Yamuna Power Limited, and are outside this contract. The cables are maintained by the College, and work at the transformer yard is limited to the cables covered by items B1 to B3. Second, the cutting, digging, trenching, chambers, refilling, fixing and making good needed to complete the items are included in the quoted rates and are not paid for separately.

6.4 Quantities marked provisional in the schedule of quantities are estimates. Payment will be made only for the work actually done and measured jointly.

6.5 Items B1 to B3 are at the transformer yard. The cables are the property of the College. The work shall be carried out under a shutdown arranged by the College with the distribution licensee, on the written instruction of the Engineer-in-Charge.

6.6 Panels covered by this work. Item A2 covers the fifteen panels listed in Table 7. Item E1 covers the ten panels marked for load balancing. The contractor and the College electrician shall walk the site together and confirm this list before work starts. A panel found on site but not listed, or listed but not found, shall be dealt with as a deviation under the contract.

Table 7 — Panels

#	Panel	Servicing, item A2	Load balancing, item E1
1	DG Changeover Panel	Yes	No
2	160 kVA DG-cum-AMF Panel	Yes	No
3	125 kVA DG Panel	Yes	No

#	Panel	Servicing, item A2	Load balancing, item E1
4	Girls Hostel AMF Panel (62.5 kVA DG)	Yes	No
5	Hostel + JDVC Main Panel (with old capacitor panel)	Yes	No
6	Admin Building Main Panel	Yes	Yes
7	Admin Ground Floor Sub Main Panel-3	Yes	Yes
8	Admin Ground Floor Sub Main Panel-4	Yes	Yes
9	Admin First Floor Panel (Sub Main Panel-7)	Yes	Yes
10	Admin Third Floor Panel	Yes	Yes
11	Hostel Panel	Yes	Yes
12	JDVC Main Panel	Yes	Yes
13	Canteen Sub Main Panel-2	Yes	Yes
14	Library Sub Main Panel-6	Yes	Yes
15	Auditorium Main Panel	Yes	Yes

7. Special conditions of contract

SC-1 Inspection of site

The contractor is advised to inspect the site and its surroundings before tendering and to satisfy himself as to access, working space, storage and the risks affecting his tender. The contractor is deemed to have full knowledge of the site whether or not he inspected it. No extra charge arising from a misunderstanding will be allowed.

SC-2 Knowledge of documents

Submission of a tender implies that the contractor has read every contract document and has satisfied himself as to the scope, the specifications, the local conditions and every other factor bearing on execution.

SC-3 Programme and phasing

The contractor shall submit a bar chart showing every activity with its start, duration and finish within seven days of the letter of intent, for the approval of the Engineer-in-Charge. Work shall proceed in stages causing the least disturbance to the occupied parts of the campus. Progress will be reviewed fortnightly.

SC-4 Working hours

Work is permitted between 09:00 and 17:00 hours on working days. Work requiring the supply to be switched off shall be done on holidays or after 17:00 hours, with the written permission of the College, at no extra cost.

SC-5 Shutdowns and live work

No work shall be carried out on a live installation. The contractor shall obtain a written shutdown permission for each panel, apply lock-out and tag-out, and confirm the supply is dead before work begins. Supply shall be restored and tested before the start of the next working day.

SC-6 Occupied campus

Every worker shall carry photo identity issued by the contractor and enter only through the gate named by the College. The campus is a women's college with a girls' hostel. Workers shall not enter hostel areas except with a College escort.

SC-7 Water and electricity

Water and electricity for the work will be made available at one point, free of cost. Distribution beyond that point and all temporary connections are at the contractor's cost. The contractor shall arrange his own storage and security.

SC-8 Rates to be inclusive

Rates shall include all labour, material, tools, plant, scaffolding, lifts and leads, and everything necessary to complete the item in all respects, whether or not specifically mentioned. Rates apply at all floors and levels. No extra is payable on any of these accounts.

SC-9 Work not specifically mentioned

Any work, supply or service not specifically mentioned in the schedule of quantities or the specifications, but necessary for the complete execution of the work, shall be provided by the contractor within the quoted rates and within the stipulated time.

SC-10 Specifications

The work shall be executed in accordance with section 9. Where the tender is silent, the current CPWD General Specifications for Electrical Works govern, with correction slips issued up to the last date of receipt of tenders. Where a doubt arises, the decision of the Engineer-in-Charge shall be final.

SC-11 Approved makes

Materials shall be of the makes at section 11. Where an item in the schedule of quantities names a make, that name governs. A substitution requires the prior written approval of the Engineer-in-Charge and shall be of equal or better specification, at no extra cost.

SC-12 Samples

The contractor shall submit samples of every material for approval within seven days of being asked. No item shall be executed before its sample is approved. Approved samples shall be retained at site until the work is accepted.

SC-13 Testing and instruments

All testing of materials and work is at the contractor's cost, including packing, transport and handling. The earth tester, thermal imaging camera, insulation tester and torque wrench used on this work shall carry valid calibration certificates. Three copies of every test record shall be given to the Engineer-in-Charge.

SC-14 Dismantled materials

Fuse units, circuit breakers, cables and fittings removed from the works remain the property of the College and shall be handed over at the College store with a written list. Debris shall be removed from the site by the contractor at his cost.

SC-15 Period of completion

The work shall be completed within 90 days from the date of start recorded in the commencement letter. Time is of the essence of this contract.

SC-16 Measurement and bills

The contractor shall submit computerised bills supported by computerised measurement sheets, in hard copy and in a spreadsheet file. Measurements shall be taken jointly. Where the contractor fails to attend, the measurements of the Engineer-in-Charge shall be binding.

SC-17 Minimum running account bill

No running account bill will be entertained for a gross value below Rs 2,00,000.

SC-18 Price variation

The contract is on a firm-price basis. No claim for escalation of labour or material rates will be entertained.

SC-19 Deviation

The College may increase or decrease any quantity, change a specification, or omit any item as necessary to complete the work within the sanctioned amount. The contractor shall carry out the varied work at the tendered rates and shall have no claim on account of the variation.

SC-20 Extra items

For an item wholly new and additional to the contract, the contractor shall submit a rate supported by a rate analysis within fifteen days. The Engineer-in-Charge shall determine the rate on market rates within forty-five days, and payment shall be made at the rate so determined.

SC-21 Taxes

Rates are exclusive of goods and services tax and inclusive of every other tax, duty, levy and cess payable by the contractor under the law in force. Goods and services tax on the contractor's inputs is the contractor's cost. Statutory variation in the rate of tax on the supply of service after the last date of receipt of tenders shall be adjusted.

SC-22 Deduction at source

Deduction of tax at source and recovery of cess shall be made from payments in accordance with the law in force during the currency of the contract. Certificates of deduction will be issued by the College.

SC-23 Cess

Cess at one per cent of the cost of construction, where payable under the law in force, will be recovered from the contractor's bills unless the contractor produces proof of direct payment.

SC-24 Defect liability period

The defect liability period is twelve months from the certified date of completion. This is a deviation from Clause 17 of the General Conditions, which gives six months for works costing Rs 10 lakh and below. The longer period is taken because the work is safety rectification of an existing installation whose defects appear over a full seasonal cycle. The security deposit will be released accordingly.

SC-25 Liquidated damages

Where the contractor fails to complete the work within the stipulated or extended time, he shall pay liquidated damages at 1 per cent of the contract value per week of delay, subject to a maximum of 5 per cent of the contract value. Liquidated damages are compensation for delay and not a penalty. This clause does not apply to delay for which an extension of time has been granted.

SC-26 Statutory compliance

The contractor shall comply with the labour, safety and tax laws in force and shall obtain and keep current every registration and licence required for this work. The contractor shall indemnify the College against any liability arising from non-compliance.

SC-27 Payment of wages

The contractor shall pay wages and statutory dues to every worker engaged on this work, directly or through a sub-contractor, on time and in full, and shall produce records on demand. The College may pay unpaid wages directly and recover the amount from the contractor.

SC-28 Welfare

No person below the age permitted by law shall be employed. Drinking water, sanitation, first aid and rest arrangements shall be provided as required by the applicable rules.

SC-29 Safety

The contractor shall, at his own cost, provide and maintain all safety measures for persons employed on the work and for others on the campus, including barricades, signage, insulated tools, safety helmets, footwear, eye protection and full-body harnesses with anchorage for work at height. Safety arrangements shall follow the CPWD Safety Code. The contractor is responsible for all liability arising from an accident on the work.

SC-30 Method statements

Panel shutdown and rectification, cable work in the transformer and generator yards, earth pit excavation and work at height are safety-critical. The contractor shall submit a method statement for each activity, and the Engineer-in-Charge shall accept it, before that activity begins. No such activity shall commence on the strength of clause SC-29 alone.

SC-31 Failure to provide safety measures

Where the contractor fails to provide the safety measures required, the Engineer-in-Charge may, after notice, make the arrangements and recover the cost from the contractor.

SC-32 Environmental controls

The contractor shall control dust, noise and waste in accordance with the directions in force in the National Capital Region, and shall dispose of construction and demolition waste only at an authorised facility, with records kept. All costs are deemed included in the rates.

SC-33 Coordination

The contractor shall coordinate with the distribution licensee, with the College electrician and with any other agency working on the campus, and shall provide access and sequencing without extra cost.

SC-34 Completion documents

Before the completion certificate is issued the contractor shall hand over: the thermal camera report taken after the repairs; the test readings of every old and new earth pit; the signed load balancing sheets; the wiring chart in AutoCAD and portable document format with three framed prints; and all test and calibration certificates.

SC-35 Integrity pact

The Integrity Pact printed with the General Conditions of Contract does not apply to this work and shall be deleted when the agreement is framed. Provision for the Integrity Pact is made only for works with estimated cost put to tender of Rs 300 crore and above.

SC-36 Force majeure

Neither party is liable for failure to perform caused by an event beyond its control, including act of God, war, riot, strike, or a criminal act beyond the control of the affected party. Negligence, wrongdoing and ordinary seasonal rain are excluded. The affected party shall give notice within fourteen days of the occurrence. The event suspends, and does not excuse, performance, and the period of completion shall be re-fixed without liquidated damages. Where performance is prevented for more than ninety days, either party may terminate the contract. On termination the contractor shall be paid for the work executed and measured up to the date of termination, and for materials brought to site and taken over by the College, and the security deposit and performance guarantee shall be released. Neither party shall have any further claim against the other.

SC-37 Settlement of disputes

A dispute shall first be referred to the decision of the College. A party dissatisfied with that decision shall give written notice within twenty-eight days, and the parties shall attempt to settle the matter by mediation. Failing settlement, the dispute shall be resolved as provided in the General Conditions of Contract. The courts at New Delhi have jurisdiction.

8. General conditions of contract

8.1 The General Conditions of Contract 2023 for Construction Works issued by the Central Public Works Department under Office Memorandum No. DG/CON/Misc./30 dated 22.09.2023, incorporating amendments up to Circular No. DG/CON/340 dated 21.08.2023, together with the CPWD Safety Code, the Model Rules for the Protection of Health and Sanitary Arrangements for Workers and the CPWD Contractor's Labour Regulations printed with them, shall govern this contract. The bidder is deemed to have read them. They are available on the CPWD website and are not reproduced here.

8.2 References in those General Conditions to the Government, the Department, the Engineer-in-Charge and the specified authorities shall be read as references to Janki Devi Memorial College and to the officers named in Table 4.

8.3 Table 4 and the special conditions at section 7 complete the contract. Where a special condition conflicts with the General Conditions, the special condition governs.

8.4 Table 4 is complete. Where an entry reads “not applicable” or “none”, that is the entry and nothing further is to be read into it.

Table 4 — Schedule F entries

Clause	Entry
Officer inviting tender	The Principal, Janki Devi Memorial College
Engineer-in-Charge	The Consultant Engineer, Janki Devi Memorial College
Accepting authority	The Principal, Janki Devi Memorial College
Clause 1, performance guarantee	5 per cent of the tendered amount, to be submitted within 7 days of the letter of intent; the Engineer-in-Charge may extend the period by up to a further 7 days with interest. It may be furnished, at the

Clause	Entry
	contractor's option, as a demand draft in favour of the College, a fixed deposit receipt of a scheduled bank pledged to the College, or a bank guarantee in the form at Annexure H
Clause 1A, security deposit	2.5 per cent of the tendered amount, recovered at 2.5 per cent of the gross amount of each running and final bill
Clause 2, compensation for delay	Authority: the Principal. Rate: 1 per cent of the contract value per week, maximum 5 per cent
Clause 5, time allowed and milestones	90 days. No milestone is fixed under clause 5.4 and no amount is withheld against a milestone. There is no sectional completion
Clause 7, minimum running account bill	Rs 2,00,000
Clause 10B(ii)	Not applicable. No advance of any kind is payable under this contract
Clauses 10C and 10CC	Not applicable. The period of completion is 90 days and the contract is on a firm-price basis
Clause 11, specifications	As at section 9 of this document
Clause 12, deviation	Authority: the Principal. This being a maintenance work, the completion cost shall not exceed 1.25 times the tendered amount. Deviation beyond that, up to 1.5 times the tendered amount, requires the Principal's approval with reasons recorded. Clause 12.4 does not apply. The digging and trenching in items B1, B7, C1, C2 and C3 are incidental to the electrical items and are not separate foundation or earthwork items
Clause 16, reduced rates	The Principal
Clause 17, defect liability period	12 months, as at clause SC-24
Clause 18, machinery and tools at site	Earth tester, thermal imaging camera, insulation tester, tong tester, torque wrench, blower
Clauses 19C, 19D, 19G and 19K	Authority: the Principal
Clause 25, disputes	Conciliator: the Principal. Arbitrator appointing authority: the Principal. Place of arbitration: New Delhi
Clause 32, technical representative	One supervisor holding a valid electrical supervisor certificate of competency, present at site whenever work is in progress. Recovery for each day on which the supervisor is not present: one day's wages of a supervisor at the market rate prevailing in Delhi on that date, as assessed by the Engineer-in-Charge, whose assessment shall be final

9. Technical specifications

9.1 The work shall conform to the CPWD General Specifications for Electrical Works, Part I (Internal) 2023 and Part II (External) 2023, with correction slips issued up to the last date of receipt of tenders.

9.2 All Indian Standards referred to in the CPWD General Specifications shall be read as the latest edition in force on the last date of receipt of tenders, including all amendments.

9.3 Every material shall conform to the Indian Standard named in the item of the schedule of quantities. Where an item names a standard, that standard governs.

9.4 All work shall be carried out by persons holding the licence or certificate of competency required in Delhi for that class of work.

9.5 On completion of each part of the work the contractor shall test it and record the results, including insulation resistance, earth resistance and the thermal scan after repair, and shall hand the records to the Engineer-in-Charge.

10. Schedule of quantities

10.1 The schedule of quantities is printed in full at Annexure I of this document. It contains 36 items in five sections. Annexure I is the financial bid. The bidder shall detach it, quote a rate against every item in figures and in words, extend each amount, total each section, total the whole, write the total in words, sign and stamp every page, and enclose it in Cover 2.

10.1.1 A copy of the schedule is also published as a spreadsheet file for the bidder's convenience in working out rates. The priced and signed Annexure I is the bid. The spreadsheet is not to be submitted.

10.2 The contract is an item-rate contract. Payment will be made on measurement at the quoted rates.

Table 5 — Sections of the schedule of quantities

Section	Description	Items
A	Checking and repair of electrical panels	11
B	Making loose and damaged cables safe	7
C	Earthing	5
D	Safety items at panel rooms, DG yard and transformer yard	11
E	Load balancing and wiring chart	2

10.3 Items marked provisional are paid only for the work actually done and measured. The College may omit any provisional item without compensation to the contractor.

11. Approved makes

11.1 Materials shall be of the makes listed in Table 6. Where an item in the schedule of quantities names a make, that name governs and this table does not override it. Where a material is not listed and no make is named in the item, the make shall be approved in writing by the Engineer-in-Charge before procurement. Any substitution requires prior written approval and shall be of equal or better specification, at no extra cost. All materials shall conform to the relevant Indian Standard, current edition, whether or not the standard is named below.

11.2 Where Table 6 states that no make is fixed, the contractor may offer any product that conforms to the Indian Standard named in the item. Before procurement the contractor shall

submit a sample and the manufacturer's test certificate and obtain the written approval of the Engineer-in-Charge. Approval will not be withheld for a product that conforms. The contractor shall allow seven days for approval and shall include that period in the programme.

Table 6 — Approved makes

#	Material	Makes
1	Switch-fuse units and HRC fuses	Larsen & Toubro, Siemens, Schneider Electric, C&S Electric
2	Moulded case circuit breakers	ABB, Siemens, Schneider Electric, Larsen & Toubro
3	Miniature circuit breakers and enclosures	ABB, Siemens, Schneider Electric, Legrand, Hager, HPL
4	Cable lugs and double-compression glands	No make is fixed. To conform to the Indian Standard named in the item and to be approved in writing by the Engineer-in-Charge before procurement
5	Galvanised iron earth pipe, earth strip and copper wire	To conform to the Indian Standard named in the item; source approved by the Engineer-in-Charge before supply
6	Hot-dip galvanised perforated cable tray	No make is fixed. Factory fabricated, to be approved in writing by the Engineer-in-Charge before procurement
7	Polyvinyl chloride conduit and accessories	No make is fixed. To be approved in writing by the Engineer-in-Charge before procurement
8	Light emitting diode batten luminaires (item D9 only)	No make is fixed. To be approved in writing by the Engineer-in-Charge before procurement
9	Exhaust fan	No make is fixed. To be approved in writing by the Engineer-in-Charge before procurement
10	Insulating mat, fire extinguisher, danger board, first-aid box and hand gloves	Products marked with the standard mark of the Bureau of Indian Standards for the standard named in the item; make approved by the Engineer-in-Charge

Confirmed for this work: Engineer _____ Date _____

12. Drawings

12.1 No drawings are issued with this tender. The installation is existing. The panels, earth pits and cable routes will be shown to the bidder at the site inspection and will be marked jointly before work begins.

12.2 The wiring chart of the campus is an output of item E2 of the schedule of quantities and is to be prepared by the contractor.

13. Forms and annexures

Annexures A to G are to be filled and enclosed in Cover 1. Annexure H is furnished by the successful bidder after award. Annexure I is the financial bid and goes in Cover 2.

Annexure A — Tender acceptance letter

To the Principal, Janki Devi Memorial College, New Delhi.

Subject: Acceptance of the terms and conditions of the tender for Electrical safety and repair works at Janki Devi Memorial College, New Delhi, tender reference JDMC/EW/2026-27/01.

1. I/We have downloaded the tender document for the above work.
2. I/We have read every page of the tender document, including the conditions, annexures, forms and schedules, and every corrigendum issued, and accept all of them unconditionally.
3. All statements and information furnished by me/us are true and correct, and nothing material has been withheld.
4. I/We understand that the College is not bound to accept the lowest or any tender, and may accept the whole or part of the tender, which I/We shall execute at the quoted rates.
5. I/We understand that if any information furnished is found false, or if I/We fail to commence the work within the stipulated time after acceptance, the College may reject the tender and take any other action available in law, and I/We shall have no claim.

Signature of the bidder _____

Name _____

Designation _____

Name and address of the firm, with stamp _____

Place _____ Date _____

Annexure B — Bidder's details

#	Particular	Detail
1	Name of the firm or company	
2	Constitution	
3	Registered address	
4	Address for correspondence	

#	Particular	Detail
5	Permanent account number	
6	Goods and services tax identification number	
7	Provident fund registration number	
8	State insurance registration number	
9	Electrical contractor licence number and validity	
10	Name of proprietor, partners or directors	
11	Name, designation, telephone and email of the authorised signatory	
12	Bank name, branch, account number and IFSC	
13	Class under the Make in India Order	
14	Micro or small enterprise registration number, if any	
15	Startup recognition number, if any	

I/We declare that the information above is true and correct. If it is found incorrect at any stage, the College may take such action as is warranted.

Signature of the bidder _____

Name _____

Designation _____

Name and address of the firm, with stamp _____

Place _____

Date _____

Annexure C — Experience and completed works

#	Name of work	Employer	Executed cost (Rs)	Date of start	Date of completion	Completion certificate reference
1						
2						

I/We certify that the works listed above were executed by us and that the completion certificates enclosed are genuine.

Signature of the bidder _____

Name _____

Designation _____

Name and address of the firm, with stamp _____

Place _____ Date _____

Annexure D — Bid securing declaration

To the Principal, Janki Devi Memorial College, New Delhi.

Bid securing declaration for Electrical safety and repair works at Janki Devi Memorial College, New Delhi, tender reference JDMC/EW/2026-27/01.

1. I/We accept that this declaration is furnished in place of bid security.
2. I/We accept that I/we shall be suspended from participating in any tender of the College for one year from the date of the event if: (a) I/we withdraw or modify the tender during the period of its validity; or (b) being the successful bidder, I/we fail to furnish the performance guarantee within the stipulated period; or (c) being the successful bidder, I/we fail to sign the agreement.
3. I/We understand that such failure may attract action under the rules in force, including suspension from tendering with the College.
4. This declaration ceases to be valid on the earlier of the expiry of the bid validity, or the furnishing of the performance guarantee and signing of the agreement by the successful bidder.

Signature of the bidder _____

Name _____

Designation _____

Name and address of the firm, with stamp _____

Place _____

Date _____

Annexure E — Affidavit that the bidder is not debarred

On non-judicial stamp paper of the value required, sworn before a notary.

I, _____, _____ of M/s
_____, solemnly affirm that:

1. The firm is not debarred by the Department of Expenditure, by Janki Devi Memorial College, or by any other procuring entity, and its name does not appear on any debarment list in force.
2. No proprietor, partner, director, trustee or office bearer of the bidder, as applicable to its constitution, has been convicted of an offence relating to corruption, or of an offence arising out of the execution of a public contract, or of an offence under the labour laws.
3. The firm has not been debarred on more than one occasion for failure to pay wages to employees engaged under a contract.
4. The firm discloses the following transgressions of the Code of Integrity in the last three years (write “nil” if there are none):

5. The firm is not under insolvency or liquidation proceedings and there is no conflict of interest in respect of this tender.

Deponent _____

Name _____

Designation _____

Place _____ Date _____

Signature, seal and registration number of the notary _____

Annexure F — Undertaking on compliance with the Labour Codes

I/We undertake that, in the execution of Electrical safety and repair works at Janki Devi Memorial College, New Delhi, we shall comply with the labour laws in force, shall obtain and keep current every registration and licence required for this work, and shall produce them on demand.

I/We further undertake to pay wages and statutory dues to every worker engaged on this work, directly or through a sub-contractor, on time and in full, and to maintain and produce wage, attendance and payment records. I/We accept that failure to do so on more than one occasion is a ground for debarment, and that the College may pay unpaid wages directly and recover the amount from us.

I/We accept liability for the cess payable at one per cent of the cost of construction, where it is payable under the law in force.

Signature of the bidder _____

Name _____

Designation _____

Name and address of the firm, with stamp _____

Place _____

Date _____

Annexure H — Form of performance guarantee

This form is not to be submitted with the tender. It is furnished by the successful bidder within 7 days of the letter of intent, and only where the guarantee is given as a bank guarantee. A demand draft or a pledged fixed deposit receipt needs no form.

To be issued or confirmed by a scheduled bank. A guarantee merely advised by a scheduled bank is not acceptable, nor is a corporate guarantee or an indemnity bond.

In consideration of Janki Devi Memorial College having agreed, under agreement number _____ dated _____ made between the College and M/s _____ for the work of Electrical safety and repair works at Janki Devi Memorial College, New Delhi, to accept a performance guarantee:

1. We, _____ bank, undertake to pay the College, on demand, an amount not exceeding Rs _____ (Rupees _____ only).
2. We undertake to pay the amount demanded without demur, merely on a demand from the College stating that the amount claimed is required to meet recoveries due or likely to become due from the contractor. Such a demand shall be conclusive as to the amount payable. Our liability is restricted to Rs _____.
3. We undertake to pay notwithstanding any dispute raised by the contractor, our liability being absolute and unequivocal. Payment by us discharges our liability and the contractor shall have no claim against us for making it.
4. This guarantee remains in force until all dues of the College are paid and its claims satisfied, or until the Engineer-in-Charge certifies that the contractor has fully carried out the terms of the agreement and discharges this guarantee.
5. The College may, without our consent and without affecting our obligations, vary the terms of the agreement, extend the time for performance, or forbear to enforce any term, and we shall not be relieved of liability.
6. This guarantee is not discharged by a change in the constitution of the bank or of the contractor, and shall not be revoked except with the previous written consent of the College.
7. This guarantee is valid up to _____, being sixty days beyond completion of all contractual obligations including the defect liability period, unless extended on demand.

Signature of the issuing officer _____

Name and designation _____

Officer code _____ Date _____

Branch, address and IFSC _____

Controlling officer's name and telephone _____

ANNEXURE I

SCHEDULE OF QUANTITIES — FINANCIAL BID (COVER 2)

Name of work: Electrical safety and repair works at Janki Devi Memorial College, New Delhi. Tender reference JDMC/EW/2026-27/01.

How to fill this annexure

1. Detach these pages from the tender document. They are the financial bid.
2. Write the rate against every item, in figures and in words, in ink, per the unit shown, excluding goods and services tax. A rate left blank, quoted as nil, or written so that it cannot be read, will cause the tender to be rejected.
3. Multiply the rate by the quantity and write the amount. Total each section, then total the whole, and write the total in words below the table.
4. Do not alter any description, unit or quantity. Any correction to a figure must be scored through, rewritten and initialled. Correction fluid must not be used.
5. Sign and stamp every page. Enclose these pages, and nothing else, in the sealed cover marked “Financial Bid”.
6. Items marked provisional are paid only for the work actually done and measured. The College may omit any provisional item without compensation.
7. Rates are for finished work, complete in all respects, and include labour, material, tools, plant, scaffolding, transport, taxes other than goods and services tax, cess, and everything necessary to complete the item. Work is to be carried out on holidays or outside college hours where the item so states, at no extra cost.

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
A	SECTION A - CHECKING AND REPAIR OF ELECTRICAL PANELS					
A1	Checking all main electrical panels with a thermal (heat) camera to find loose or overheating connections. The check is done twice: once before repair work starts and once after all repairs are finished. A trained person shall do the check and give a printed report with a photograph of each overheating point, panel name and location. Any point still found hot after repair shall be repaired again at no extra cost.	Day	2			

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
A2	Servicing of electrical panel (the fifteen panels are listed at section 6.6 of the tender document): switch off supply with written permission of the college; remove dust with blower and cloth; tighten all nuts, bolts and cable connections including busbar joints; clean and re-fix loose or blackened cable ends; remove open joints and make proper connections; close open holes in the panel with metal plates; refit missing covers and screws; fix a lasting name label on every switch; for the old non-functional capacitor panel, switch off and lock its incoming switch and fix a NOT IN USE board. Work on holidays or after college hours.	Each	15			
A3	Replacing a burnt or overheated fuse unit in an existing panel with a new 315 A four-pole (TP&N) switch-fuse unit with ISI marked HRC fuses, including drilling, fixing and connections. Rating to match the existing unit. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 2.1.7]	Each	2			
A4	Same as item A3 but 160 A four-pole (TP&N) switch-fuse unit with ISI marked HRC fuses. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 2.1.5]	Each	2			
A5	Replacing a burnt or overheated circuit breaker (MCCB) in an existing panel with a new 250 A, 25 kA, three-pole MCCB, including drilling, fixing and connections. Rating to match the existing breaker. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 2.2.6]	Each	1			

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
A6	Same as item A5 but 150 A, 16 kA, three-pole MCCB. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 2.2.3]	Each	1			
A7	Same as item A5 but 125 A, 16 kA, three-pole MCCB. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 2.2.2]	Each	1			
A8	Making a new cable end (new aluminium lugs and brass cable gland) where the old cable end is burnt or damaged, for cable size 3.5 core x 300 sq mm. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 11.1.30]	Each	4			
A9	Same as item A8, for cable size 3.5 core x 95 sq mm. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 11.1.24]	Each	6			
A10	Same as item A8, for cable size 3.5 core x 35 sq mm. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 11.1.21]	Each	8			
A11	Same as item A8, for cable size 4 core x 16 sq mm. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 11.1.33]	Each	6			
	Total of Section A					
B	SECTION B - MAKING LOOSE AND DAMAGED CABLES SAFE					
B1	Transformer yard: taking the existing LT cables that lie open on the ground and laying them in a proper trench with sand below and above and bricks on top, then refilling. Rate for the first cable in the trench, cable size above 185 up to 400 sq mm. This item shall be done under a shutdown arranged by the college.	Metre	15			

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
	(Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 10.1.4]					
B2	Same as item B1, for each additional cable laid in the same trench, cable size above 185 up to 400 sq mm. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 10.2.4]	Metre	15			
B3	Where the outer cover of the transformer yard cable is badly cracked: cutting out the damaged part and joining the cable with a heat-shrink straight joint kit, cable size 3.5 core x 300 sq mm. Only where needed and approved at site. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 11.4.27]	Each	2			
B4	DG yard: supplying and fixing 100 mm wide galvanised (GI) perforated cable tray with supports, for the hanging cables between the 125 kVA DG set and the panel room. [CPWD DSR (E&M) 2025 item 4.6.1]	Metre	15			
B5	Laying and clamping the existing DG cable on the above cable tray, cable size above 95 up to 185 sq mm. [CPWD DSR (E&M) 2025 item 10.8.3]	Metre	15			
B6	Supplying and fixing 25 mm PVC pipe (conduit) with fittings on the wall to cover loose and hanging wires in panel rooms and the DG yard. Existing wires shall be drawn into the conduit. [CPWD DSR (E&M) 2025 item 1.21.2]	Metre	50			
B7	Hostel/JDVC panel room: taking the existing cables (size up to 35 sq mm) that lie open outside the panel room and laying them in a trench with sand below and above and bricks on top, then refilling. [CPWD DSR (E&M) 2025 item 10.1.1]	Metre	15			
	Total of Section B					

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
C	SECTION C - EARTHING					
C1	Old earth pits that are now buried: dig to find each pit; clean the pit connection and earth strip joints; build a small brick chamber (about 300 x 300 mm inside) with a hinged cover and lock; test the pit with an earth tester; paint the pit number, equipment connected and test reading on the cover. Test readings to be given in writing. (Provisional quantity - payment only for work actually done and measured.)	Each	12			
C2	Making a new earth pit with 40 mm GI pipe 4.5 m long, brick chamber with lockable cover and watering pipe (without charcoal and salt), including testing. For the DG sets, DG changeover panel and Hostel/JDVC panel, only where an old pit is missing or fails the earth-resistance test. Location to be marked at site. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 5.1]	Each	10			
C3	Laying 25 x 5 mm GI earth strip inside 40 mm GI pipe underground from the earth pit to the equipment, including digging, refilling and nut-bolt connections. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 5.11]	Metre	60			
C4	Fixing 25 x 5 mm GI earth strip on wall or surface to connect DG set body, DG neutral and panels to the earth leads. (Provisional quantity - payment only for work actually done and measured.) [CPWD DSR (E&M) 2025 item 5.15]	Metre	30			
C5	Connecting panel doors and steel gates/shutters of panel rooms to earth with 4 mm copper wire fixed on the surface. [CPWD DSR (E&M) 2025 item 5.17]	Metre	40			
	Total of Section C					

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
D	SECTION D - SAFETY ITEMS AT PANEL ROOMS, DG YARD AND TRANSFORMER YARD					
D1	Danger board (200 x 150 mm enamelled steel plate with red letters) fixed on each panel, at the DG yard and at the transformer yard. [CPWD DSR (E&M) 2025 item 2.21]	Each	15			
D2	Electrical rubber mat, ISI marked (IS 15652), 2 mm thick, 1 metre wide, laid in front of panels.	Metre	24			
D3	Fire extinguisher, dry powder type, 9 kg, ISI marked, with wall bracket, fixed near panels, at the DG yard and at the transformer yard.	Each	6			
D4	Refilling (recharging) existing expired fire extinguishers kept near panels. (Provisional quantity - payment only for work actually done and measured.)	Each	2			
D5	Fire bucket stand with roof cover and 4 buckets filled with dry sand, fixed at the transformer yard and the DG yard.	Each	2			
D6	Safety set for each main panel room: 1 wall-mounted first-aid box with basic items, 1 framed electric shock treatment chart (Hindi and English), and 1 pair electrical rubber hand gloves (ISI marked, suitable for 1,100 V).	Set	3			
D7	Supplying 300 mm heavy-duty exhaust fan (ISI marked) for the Hostel/JDVC panel room and the Admin main panel room.	Each	2			
D8	Fixing the above exhaust fan in the existing wall opening, including connections and making good. [CPWD DSR (E&M) 2025 item 1.50.1]	Each	2			
D9	DG yard lighting: supplying and fixing 36 W LED batten light with aluminium body, including connections. [CPWD DSR (E&M) 2025 item 8.9.3 (Slip 1)]	Each	4			

S. No.	Description of work	Unit	Qty	Rate in figures (Rs)	Rate in words (Rs)	Amount (Rs)
D10	Wiring for the above lights with 2 x 1.5 sq mm + 1 x 1.5 sq mm (earth) copper wire in steel conduit on the surface. [CPWD DSR (E&M) 2025 item 1.7.1]	Metre	20			
D11	Switch for DG yard lights: 25/32 A double-pole MCB in a steel box fixed on the wall, with connections. [CPWD DSR (E&M) 2025 item 2.16]	Each	1			
	Total of Section D					
E	SECTION E - LOAD BALANCING AND WIRING CHART					
E1	Balancing the load on each distribution panel (the ten panels are listed at section 6.6 of the tender document): measure the current in each of the three phases; shift single-phase circuits from the heavily loaded phase to the lightly loaded phase; measure again; write the before and after readings on a sheet signed by the college electrician.	Each	10			
E2	Wiring chart (single line diagram) of the campus: trace where each main cable goes from the transformer and DG sets to every panel; note switch ratings and cable sizes; trace the earth wires and remove incorrect neutral-to-earth joints where found, after approval. Give the chart as a computer drawing (AutoCAD DWG and PDF) and 3 framed A1 prints fixed in the main panel room, the Hostel/JDVC panel room and the Admin office.	Job	1			
	Total of Section E					
	TOTAL AMOUNT QUOTED, excluding goods and services tax					

Total amount quoted, in words (Rupees) _____
 _____ only.

I/We have quoted the above rates after inspecting the site and reading the whole tender document including every corrigendum. I/We agree to execute the work at these rates.

Signature of the bidder

Name and designation

Name and address of the firm, with stamp

Place

Date